

Annexure-C

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

It is certified that an inspection team headed by **Er. Ganesh Kumar, Junior Engineer** from **Jal Shakti Vibhag PHED** inspected the **Gokul Montessori Sr. Sec. School Nehrian (Dukhi)** on **22.09.2026** and on the basis of Water Test Report **(Attached)** bearing No. JSV-WTL-Amb-2026-245 dated 02.09.2026 of Jal Shakti Divisional Laboratory at Amb (PHED Lab) certified that the **Gokul Montessori Sr. Sec. School Nehrian (Dukhi)** has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Government.

This certificate is issued on dated: - **22.09.2026**.


Assistant Engineer,
Jal Shakti Sub Division Amb
Distt. Una HP/177203
✉.aejsvamb812@gmail.com

To

✓ **Principal,**
Gokul Montessori
Sr. Sec. School Nehrian (Dukhi)

**HIMACHAL PRADESH
SUB DIVISIONAL WATER TESTING LABORATORY
JAL SHAKTI DIVISION, AMB**

TEST REPORT

Test Report No:-JSVWTL-AMB-2026-27:- 245				Date:- 02.09.2026	
Name & Address of Customer: Principal, Gokul Montessori Sr. Sec. School, Nehrian, Distt. Una (H.P.)					
Sampling Method:	N/A		Condition of Sample When Received:		OK
Sample Description:	Water		Name of Source/Scheme:		WSS to IPH Water Supply
Sample Quantity:	250 ml		Name of Panchayat:		Nehri
Collected On:	31.08.2026		Name of Habitation:		IPH Water Supply Tap in School
Test Start Date:	31.08.2026		Name of Village:		Duhki
Test End Date:	02.09.2026		Type of Source:		Bore

S.No.	Test	Result	Requirements As per IS 10500:2012	
			Acceptable Limit	Permissible Limit in the absence of Alternate Source

Physical Parameters

1	Temperature (° C)	25.8° C	----	----
---	-------------------	---------	------	------

Chemical Parameters

2	Nitrate (as NO ₃), mg/l, Max.	NP	45 mg/l Max	No Relaxation
3	Flouride(as F), mg/l, Max.	NP	1.0 mg/l Max	1.5 mg/l Max
4	Sulphate (as SO ₄), mg/l, Max.	NP	200 mg/l Max	400 mg/l Max
5	Ammonia (as Total Ammonia-N), mg/l, Max.	NP	0.5 mg/l Max	No Relaxation
6	Iron (as Fe), mg/l, Max.	NP	1.0 mg/l Max	No Relaxation
7	Manganese(as Mn), mg/l, Max.	NP	0.1 mg/l Max	0.3 mg/l Max
8	Total Arsenic (as As), mg/l, Max.	NP	0.01 mg/l Max	No Relaxation
9	Free Residual Chlorine, mg/l, Min.	0.2	0.2 mg/l Min	1.0 mg/l Min

Bacteriological Parameters

10	Total Coliform Bacteria (Shall not be detectable in any 100 ml sample)	Nil	Nil	Nil	Nil
11	E.Coli (Shall not be detectable in any 100 ml sample)	Nil	Nil	Nil	Nil

Remarks (if any) BDL = Below Detection Limit ; DL = Detection Limit ; NP = Not Performed

Prepared By


Sub Divisional Water Testing Laboratory
Jal Shakti Division, Amb


Authorized Signatory

Rajesh Sharma
Assistant Chemist
Sub Divisional Water Testing Laboratory
Jal Shakti Division, Amb

HIMACHAL PRADESH
SUB DIVISIONAL WATER TESTING LABORATORY
JAL SHAKTI DIVISION, AMB

TEST REPORT

Test Report No:-JSVWTL-AMB-2026-27:- 245				Date:- 02.09.2026	
Name & Address of Customer: Principal, Gokul Montessori Sr. Sec. School, Nehrian, Distt. Una (H.P.)					
Sampling Method:	N/A		Condition of Sample When Received:	OK	
Sample Description:	Water		Name of Source/Scheme:	WSS to IPH Water Supply	
Sample Quantity:	2 Ltr		Name of Panchayat:	Nehri	
Collected On:	31.08.2026		Name of Habitation:	IPH Water Supply Tap in School	
Test Start Date:	31.08.2026		Name of Village:	Duhki	
Test End Date:	02.09.2026		Type of Source:	Bore	

S.No.	Test	Test Method	Result	Requirements As per IS 10500:2012	
				Acceptable Limit	Permissible Limit in the absence of Alternate Source

Physical Parameters

1	Turbidity , NTU , Max.	IS 3025 (PART - 10): 2023	1.1	1 NTU	5 NTU
2	Colour, Hazen Unit, Max.	IS 3025 (PART - 4): 2021	BDL(DL-5)	5	15
3	Odour	IS 3025 (PART - 5): 2018	Agreeable	Agreeable	Agreeable
4	Taste	IS 3025 (PART - 7 & 8): 2022 & 2023	NP	Agreeable	Agreeable
5	pH @ 25° C	IS 3025 (PART - 11): 2022	7.86	6.5 - 8.5	No Relaxation
6	Total Dissolved Solids (Dried @180° C), mg/l, Max.	IS 3025 (PART - 16): 2023	320	500 mg/l	2000 mg/l

Chemical Parameters

7	Total Alkalinity (as CaCO ₃), mg/l, Max.	IS 3025 (PART - 23): 2023	236	200 mg/l	600 mg/l
8	Chloride (as Cl), mg/l, Max.	IS 3025 (PART - 32): 2019	19.85	250 mg/l	1000 mg/l
9	Total Hardness (as CaCO ₃), mg/l, Max.	IS 3025 (PART - 21): 2023	188	200 mg/l	600 mg/l
10	Calcium (as Ca), mg/l, Max.	IS 3025 (PART - 40): 2024	48.89	75 mg/l	200 mg/l
11	Magnesium (as Mg), mg/l, Max.	IS 3025 (PART - 46): 2023	16.03	30 mg/l	100 mg/l

Remarks (if any) **BDL** = Below Detection Limit ; **DL** = Detection Limit ; **NP** = Not Performed

Note:

This report should not be produced partly or full without approval of signatory authority.

The results refer only to tested samples and parameters tested.

Samples will be stored for a period of 5 days from the date of issue of report

Prepared By


Sub Divisional Water Testing Laboratory
Jal Shakti Division, Amb

Authorized Signatory

Rajesh Sharma

Assistant Chemist

Sub Divisional Water Testing Laboratory
Jal Shakti Division, Amb